

1 **EU - TYPE EXAMINATION CERTIFICATE**

2 **Safety Device, Controlling Device or Regulating Device intended for use outside a potentially explosive atmosphere but required for or contributing to the safe functioning of Equipment and Protective Systems with respect to the risks of explosion  
Directive 2014/34/EU**

3 EU - Type Examination Certificate Number: **Baseefa07ATEX0213 – Issue 7**

3.1 In accordance with Article 41 of Directive 2014/34/EU, EC-Type Examination Certificates referring to 94/9/EC that were in existence prior to the date of application of 2014/34/EU (20 April 2016) may be referenced as if they were issued in accordance with Directive 2014/34/EU. Supplementary Certificates to such EC-Type Examination Certificates, and new issues of such certificates, may continue to bear the original certificate number issued prior to 20 April 2016.

4 Product: **MTL5541 / MTL5541-T / MTL5544 Repeater Power Supply, 4/20mA for 2 or 3-Wire Transmitters**

5 Manufacturer: **Eaton Electric Limited**

6 Address: **Great Marlings, Butterfield, Luton, Bedfordshire, LU2 8DL**

7 This re-issued certificate extends EC Type Examination Certificate No. Baseefa07ATEX0213 to apply to product designed and constructed in accordance with the specification set out in the Schedule of the said certificate but having any variations specified in the Schedule attached to this certificate and the documents therein referred to.

8 SGS Baseefa, Notified Body number 1180, in accordance with Article 17 of Directive 2014/34/EU of the European Parliament and of the Council, dated 26 February 2014, certifies that this product has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of products intended for use in potentially explosive atmospheres given in Annex II to the Directive.

The examination and test results are recorded in confidential Report No. **See Certificate History**

9 Compliance with the Essential Health and Safety Requirements has been assured by compliance with:

**EN 60079-0: 2012 + A11: 2013 EN 60079-11: 2012**

except in respect of those requirements listed at item 18 of the Schedule.

10 If the sign “X” is placed after the certificate number, it indicates that the product is subject to the Specific Conditions of Use specified in the schedule to this certificate.

11 This EU - TYPE EXAMINATION CERTIFICATE relates only to the design and construction of the specified product. Further requirements of the Directive apply to the manufacturing process and supply of this product. These are not covered by this certificate.

12 The marking of the product shall include the following :

⊕ II (1) GD [Ex ia Ga] IIC  
[Ex ia Da] IIIC See Certificate Schedule for ambient temperature range  
⊕ I (M1) [Ex ia Ma] I

SGS Baseefa Customer Reference No. **0703**

Project File No. **18/0066**

This document is issued by the Company subject to its General Conditions for Certification Services accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and the Supplementary Terms and Conditions accessible at <http://www.sgs.com/SGSBaseefa/Terms-and-Conditions.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained herein reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. It does not necessarily indicate that the equipment may be used in particular industries or circumstances. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, schedule included, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

**SGS Baseefa Limited**


Rockhead Business Park, Staden Lane,  
Buxton, Derbyshire SK17 9RZ

Telephone +44 (0) 1298 766600 Fax +44 (0) 1298 766601

e-mail [baseefa@sgs.com](mailto:baseefa@sgs.com) web site [www.sgs.co.uk/baseefa](http://www.sgs.co.uk/baseefa)

Registered in England No. 4305578.

Registered address: Rossmore Business Park, Ellesmere Port, Cheshire, CH65 3EN

  
R S SINCLAIR  
TECHNICAL MANAGER  
PP DB/RE/AM/LS  
CERTIFICATION  
MANAGER

On behalf of SGS Baseefa Limited

13 **Schedule**

14 **Certificate Number Baseefa07ATEX0213 – Issue 7**

15 **Description of Product**

The MTL5544 Two Channel Repeater Power Supply, 4/20mA for 2 or 3-Wire Transmitters is designed to provide a floating d.c. supply for energising two conventional 2 or 3-Wire 4/20mA transmitters or a ‘smart’ transmitter in the hazardous area and repeat these currents in the non-hazardous area, whilst restricting the transfer of energy from the unspecified non-hazardous area apparatus to the intrinsically safe circuits by the means of limitation of voltage and current. The apparatus also allows bi-directional signal communication between the hazardous and non-hazardous area by the connection of a hand-held communicator (HHC).

The MTL5544 Two Channel Repeater Power Supply, 4/20mA for 2 or 3-Wire Transmitters comprises four isolating transformers that provide galvanic isolation between the hazardous and non-hazardous area circuitry, zener diode chains and resistors providing voltage and current limitation. The above, together with other electronic components are mounted on a single printed circuit board (PCB) and housed in a moulded plastic enclosure. Polarised plugs and sockets are provided for hazardous and non-hazardous area connections. A power indicator LED is fitted to the top of the equipment.

The MTL5541 Single Channel Repeater Power Supply, 4/20mA for 2 or 3-Wire Transmitters is a depopulated version of the MTL5544 and has only one channel populated.

The MTL5541-T Single Channel Repeater Power Supply, 4/20mA for 2 or 3-Wire Transmitters is of similar construction to the MTL5541 variants of the equipment with the same input and output parameters, but has an extended ambient temperature range.

The following table details the ambient temperature ranges of each variant of the equipment.

Model Variant	Ambient Temperature Range
MTL5541 Single Channel Repeater Power Supply, 4/20mA for 2 or 3-Wire Transmitters	$-20^{\circ}\text{C} \leq T_a \leq +60^{\circ}\text{C}$
MTL5541-T Single Channel Repeater Power Supply, 4/20mA for 2 or 3-Wire Transmitters	$-20^{\circ}\text{C} \leq T_a \leq +65^{\circ}\text{C}$
MTL5544 Two Channel Repeater Power Supply, 4/20mA for 2 or 3-Wire Transmitters	$-20^{\circ}\text{C} \leq T_a \leq +60^{\circ}\text{C}$

**Input / Output Parameters**

Non-Hazardous Area Terminals 7 to 14 (10 to 14 on MTL5541 model)

$$U_m = 253\text{V r.m.s.}$$

The circuit connected to non-hazardous area terminals is designed to operate from a d.c. supply voltage of up to 35V.

Hazardous Area Terminals 2 w.r.t. 1 (Channel 1)

Or

Hazardous Area Terminals 5 w.r.t. 4 (Channel 2 – MTL5544 Model Only)

$$\begin{aligned} U_o &= 28\text{V} & C_i &= 0 \\ I_o &= 93\text{mA} & L_i &= 0 \\ P_o &= 0.65\text{W} \end{aligned}$$

Hazardous Area Terminals 3 w.r.t. 1 (Channel 1)

or

Hazardous Area Terminals 6 w.r.t 4 (Channel 2 – MTL5544 Model only)

$$\begin{aligned} U_o &= 1.1\text{V} & C_i &= 0 & U_i &= 30\text{V} \\ I_o &= 53\text{mA} & L_i &= 0 & I_i &= 121\text{mA} \\ P_o &= 15\text{mW} \end{aligned}$$

When an intrinsically safe source is connected to these terminals it should have a source resistance of  $U_i / I_i$  and the capacitance and either the inductance or inductance to resistance ratio ( $L/R$ ) of the hazardous area connections must not exceed the values detailed in the certificate of the intrinsically safe source. Hazardous area terminals 2 and 5 must not be used when the above source is connected to these terminals.

Hazardous Area Terminals 2 w.r.t. 3 (Channel 1)

Or

Hazardous Area Terminals 5 w.r.t. 6 (Channel 2 – MTL5544 Models Only)

$$\begin{array}{ll} U_o = 28V & C_i = 0 \\ I_o = 87mA & L_i = 0 \\ P_o = 0.61W & \end{array}$$

Each channel must be considered as a separate intrinsically safe circuit.

### Load Parameters

The capacitance and either the inductance or inductance to resistance ratio ( $L/R$ ) of the load connected must not exceed the following values:

GROUP	CAPACITANCE ( $\mu F$ )	INDUCTANCE (mH)	OR	L/R RATIO ( $\mu H/ohm$ )
Hazardous Area Terminals 2 w.r.t. 1 or 5 w.r.t. 4				
IIC	0.083	4.2		56
IIB*	0.65	12.6		210
IIA	2.15	33.6		444
I	3.76	53.7		668
Hazardous Area Terminals 3 w.r.t. 1 or 6 w.r.t. 4				
IIC	100	12.8		2,438
IIB*	1,000	47.8		8,932
IIA	1,000	104.7		18,140
I	1,000	156.2		28,229
Hazardous Area Terminals 2 w.r.t. 3 or 5 w.r.t. 6				
IIC	0.083	4.9		59
IIB*	0.65	20.0		222
IIA	2.15	40.9		469
I	3.76	59.1		710

\* Group IIB parameters also applicable for associated apparatus [Ex ia Da] IIIC

Notes:

- The above load parameters apply when one of the two conditions below is given:
  - the total  $L_i$  of the external circuit (excluding the cable) is  $< 1\%$  of the  $L_o$  value or
  - the total  $C_i$  of the external circuit (excluding the cable) is  $< 1\%$  of the  $C_o$  value.
- The above parameters are reduced to 50% when both of the two conditions below are given:
  - the total  $L_i$  of the external circuit (excluding the cable) is  $\geq 1\%$  of the  $L_o$  value and
  - the total  $C_i$  of the external circuit (excluding the cable) is  $\geq 1\%$  of the  $C_o$  value.

The reduced capacitance of the external circuit (including cable) shall not be greater than  $1\mu F$  for Groups IIB, IIA & I and  $600nF$  for Group IIC.

The values of  $L_o$  and  $C_o$  determined by this method shall not be exceeded by the sum of all the  $L_i$  plus cable inductances in the circuit and the sum of all of the  $C_i$  plus cable capacitances respectively.

### 16 Report Number

See Certificate History

**17 Specific Conditions of Use**

None

**18 Essential Health and Safety Requirements**

In addition to the Essential Health and Safety Requirements (EHSRs) covered by the standards listed at item 9, the following are considered relevant to this product, and conformity is demonstrated in the report:

Clause	Subject	Compliance
1.2.7	Protection against other hazards (LVD type requirements, etc.)	Manufacturer responsibility
1.2.8	Overloading of equipment (protection relays, etc.)	User/Installer responsibility
1.4.1	External effects	User/Installer responsibility
1.4.2	Aggressive substances, etc.	User/Installer responsibility

**19 Drawings and Documents**

New drawings submitted for this issue of certificate:

Number	Sheet	Issue	Date	Description
CI4541-1	1 of 8	4	9.15	Parts List for MTL4541 / MTL4544
CI4541-1	4 of 8	5	1.18	MTL4541 / MTL4544 Track Layout
CI4541-1	4A of 8	5	1.18	MTL4541 / MTL4544 Track Layout
CI4541-T-1	1 & 2	1	1.18	Circuit Diagram for the MTL5541-T
CI4541-T-2	1 of 1	1	1.18	Parts List for MTL5541-T
CI4541-T-3	1 & 2	1	1.18	MTL5541-T Track Layout
CI4541-T-4	1 of 1	1	1.18	MTL5541-T Component Layout
CI4541-T-6	1 of 1	1	1.18	PCB Detail for TPL300
CI4541-T-7	1 of 1	1	1.18	PCB Detail for TPL301
CI5541-T-1	1 of 1	1	1.18	MTL5541-T IECEx Certification Label Details and DIN Rail Fittings - Baseefa

The above drawings are associated and held with IECEx BAS 07.0069 Iss. 8

Current drawings which remain unaffected by this issue:

Number	Sheet	Issue	Date	Description
CI4541-1	2 of 8	5	07.09	Circuit Diagram for MTL4541 / 4544
CI4541-1	3 of 8	5	07.09	Circuit Diagram for MTL4541 / 4544
CI4541-1	5 of 8	6	1.13	MTL4541 Component Layout
CI4541-1	6 of 8	2	1.07	PCB Detail for TPL300
CI4541-1	7 of 8	2	1.07	PCB Detail for TPL301
CI4500-3	1 of 1	1	12.10	MTL4500 & MTL5500 – Alternative Zener Diodes (Panjit)
CI4500-5	1 of 1	1	11.10	MTL5500 – Alternative DIN Rail Mechanism
CI4500-6	1 of 1	1	20.12.10	MTL4500 & MTL5500 – Conformal Coating
CI5500-100	1 of 1	3	1.13	New 5500 Outline
CI5541-1	1 of 1	5	7.16	MTL5541 Certification Label Details & DIN Rail Fittings – Baseefa

The above drawings are associated and held with IECEx Certificate No. IECEx BAS 07.0069

20 Certificate History

Certificate No.	Date	Comments
Baseefa07ATEX0213	12 November 2007	The release of the prime certificate. The associated test and assessment against the requirements of EN 60079-0: 2006, EN 60079-11: 2007 and EN 61241-11: 2006 is documented in Certification Report No. GB/BAS/ExTR07.0129/00.
Baseefa07ATEX0213/1	4 January 2008	To permit minor changes to the PCB layout not affecting the original assessment.
Baseefa07ATEX0213/2	21 August 2009	<ul style="list-style-type: none"> <li>i) To permit an alternative printed circuit board to be fitted in all models of the equipment not affecting the original assessment.</li> <li>ii) To permit minor drawing changes not affecting the original assessment.</li> </ul> <p>The associated test and assessment is documented in Certification Report No. GB/BAS/ExTR09.0124/00.</p>
Baseefa07ATEX0213/3	28 June 2010	<ul style="list-style-type: none"> <li>i) To permit minor component changes to all models of the equipment not affecting the original assessment.</li> <li>ii) To permit the notes associated with the load parameters of all models specified on the original schedule to be revised.</li> <li>iii) To confirm the current designs of the MTL5541 / MTL5544 Repeater Power Supply, 4/20mA for 2 or 3-Wire Transmitters have been reviewed against the requirements of EN 60079-0: 2009 in respect of the differences from EN 60079-0: 2006, and with exception of the marking, none of the differences affect the equipment. In accordance with the requirements of EN 60079-0: 2009, the equipment markings were revised to include the Equipment Protection Level (EPL) markings.</li> </ul> <p>The associated test and assessment is documented in Certification Report No. GB/BAS/ExTR10.0101/00.</p>
Baseefa07ATEX0213/4	31 January 2011	<ul style="list-style-type: none"> <li>i) To permit the alternative fitting of 1SMB3EZ** zener diodes in place of 1SMB59**BT3 components currently fitted.</li> <li>ii) To permit an alternative method of applying the conformal coating to the PCB fitted in the equipment not affecting the original assessment.</li> <li>iii) To permit the use of an alternative DIN rail mechanism not affecting the original assessment.</li> </ul> <p>The associated test and assessment is documented in Certification Report No. GB/BAS/ExTR10.0298/00.</p>

Certificate No.	Date	Comments
Baseefa07ATEX0213/5	5 March 2014	<p>i) To permit minor drawing changes not affecting the original assessment.</p> <p>ii) To confirm the current designs of the MTL5541 / MTL5544 Repeater Power Supply, 4/20mA for 2 or 3-Wire Transmitters have been reviewed against the requirements of EN 60079-0: 2012 and EN 60079-11: 2012 in respect of the differences from EN 60079-0: 2009, EN 60079-11: 2007 &amp; EN 61241-11: 2006 and none of the differences affect the equipment. In accordance with EN 60079-11: 2012, the Group I capacitive load parameters were corrected and the associated load parameter notes were updated.</p> <p>The associated test and assessment is documented in Certification Report No. GB/BAS/ExTR14.0043/00.</p>
Baseefa07ATEX0213 Issue 6	5 October 2016	<p>This issue of the certificate incorporates previously issued primary &amp; supplementary certificates into one certificate and confirms the current designs meet the requirements of EN 60079-0: 2012 + A11: 2013 &amp; EN 60079-11: 2012.</p> <p>The certificate also permits the manufacturer's name to be changed on page 1 of the certificate and on the equipment marking.</p> <p>The associated assessment is documented in Certification Report No. GB/BAS/ExTR16.0238/00.</p>
Baseefa07ATEX0213 Issue 7	9 February 2018	<p>This issue of the certificate permits the addition of the MTL5541-T Single Channel Repeater Power Supply, 4/20mA for 2 or 3-Wire Transmitters variant to the range covered by the certificate.</p> <p>The MTL5541-T is of similar construction to the MTL5541 variant and has the same input and output parameters, but has an extended ambient temperature range of -20°C to +65°C. The Certificate title &amp; marking sections and Schedule have been revised to include the new variant details.</p> <p>This issue also permits minor drawing changes not affecting the original assessment.</p> <p>The associated assessment is documented in Certification Report No. GB/BAS/ExTR18.0016/00, Project File No. 18/0066.</p>
For drawings applicable to each issue, see original of that issue.		