

1 **EU - TYPE EXAMINATION CERTIFICATE**

2 **Safety Device, Controlling Device or Regulating Device intended for use outside a potentially explosive atmosphere but required for or contributing to the safe functioning of Equipment and Protective Systems with respect to the risks of explosion  
Directive 2014/34/EU**

3 EU - Type Examination Certificate Number: **Baseefa14ATEX0157 – Issue 2**

3.1 In accordance with Article 41 of Directive 2014/34/EU, EC-Type Examination Certificates referring to 94/9/EC that were in existence prior to the date of application of 2014/34/EU (20 April 2016) may be referenced as if they were issued in accordance with Directive 2014/34/EU. Supplementary Certificates to such EC-Type Examination Certificates, and new issues of such certificates, may continue to bear the original certificate number issued prior to 20 April 2016.

4 Product: **MTL4573 & MTL4573Y Temperature Converter**

5 Manufacturer: **Eaton Electric Limited**

6 Address: **Great Marlings, Butterfield, Luton, Bedfordshire, LU2 8DL**

7 This re-issued certificate extends EC Type Examination Certificate No. Baseefa14ATEX0157 to apply to product designed and constructed in accordance with the specification set out in the Schedule of the said certificate but having any variations specified in the Schedule attached to this certificate and the documents therein referred to.

8 SGS Baseefa, Notified Body number 1180, in accordance with Article 17 of Directive 2014/34/EU of the European Parliament and of the Council, dated 26 February 2014, certifies that this product has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of products intended for use in potentially explosive atmospheres given in Annex II to the Directive.

The examination and test results are recorded in confidential Report No. See Certificate History

9 Compliance with the Essential Health and Safety Requirements has been assured by compliance with:

**EN 60079-0: 2012 + A11: 2013 EN 60079-11: 2012**

except in respect of those requirements listed at item 18 of the Schedule.

10 If the sign “X” is placed after the certificate number, it indicates that the product is subject to the Specific Conditions of Use specified in the schedule to this certificate.

11 This EU - TYPE EXAMINATION CERTIFICATE relates only to the design and construction of the specified product. Further requirements of the Directive apply to the manufacturing process and supply of this product. These are not covered by this certificate.

12 The marking of the product shall include the following :

⊕ II (1) GD [Ex ia Ga] IIC (-20°C ≤ T<sub>a</sub> ≤ +60°C)  
[Ex ia Da] IIIC (-20°C ≤ T<sub>a</sub> ≤ +60°C)

⊕ I (M1) [Ex ia Ma] I (-20°C ≤ T<sub>a</sub> ≤ +60°C)

SGS Baseefa Customer Reference No. 0703

Project File No. 16/0371

This document is issued by the Company subject to its General Conditions for Certification Services accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and the Supplementary Terms and Conditions accessible at <http://www.sgs.com/SGSBaseefa/Terms-and-Conditions.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained herein reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. It does not necessarily indicate that the equipment may be used in particular industries or circumstances. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, schedule included, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

**SGS Baseefa Limited**

Rockhead Business Park, Staden Lane,  
Buxton, Derbyshire SK17 9RZ

Telephone +44 (0) 1298 766600 Fax +44 (0) 1298 766601  
e-mail [baseefa@sgs.com](mailto:baseefa@sgs.com) web site [www.sgs.co.uk/baseefa](http://www.sgs.co.uk/baseefa)

Registered in England No. 4305578.

Registered address: Rossmore Business Park, Ellesmere Port, Cheshire, CH65 3EN



R S SINCLAIR  
TECHNICAL MANAGER  
On behalf of SGS Baseefa Limited

13

## Schedule

14

Certificate Number Baseefa14ATEX0157 – Issue 2

### 15 Description of Product

The MTL4573 & MTL4573Y Temperature Converters are designed to restrict the transfer of energy from unspecified non-hazardous area equipment to either thermocouples or RTD's located in the hazardous area by limitation of voltage and current. A transformer and opto-isolator provide galvanic isolation between the hazardous and non-hazardous area circuitry.

The MTL4573 & MTL4573Y Temperature Converters are designed for connection to thermocouples or two, three or four wire RTD's situated in the hazardous area. The apparatus converts the low level d.c. signal from the sensor mounted in the hazardous area into a 4/20mA current for driving a load in the non-hazardous area. An optional cold junction compensation (CJC) plug can be fitted to the hazardous area connections which alters the internal connections and affects the output parameters.

The equipment comprises an isolating transformer, an opto-isolator, duplicated zener diode chains and current limiting resistors to provide voltage and current limitation. The above, together with other electronic components are mounted on a printed circuit board (PCB) and housed in a moulded plastic enclosure. Polarised plugs and sockets are provided for hazardous and non-hazardous area connections. A jack socket is provided for the connection of a suitably certified data terminal for programming the equipment.

The MTL4573Y Temperature Converter differs from the MTL4573 with regard to the configuration of the non-hazardous area circuitry. In terms of intrinsic safety, both are identical.

### Input / Output Parameters

#### Non-Hazardous Area Terminals 8, 9, 11, 13 & 14

$$U_m = 253V \text{ r.m.s.}$$

The circuit connected to non-hazardous area terminals 8, 9, 11, 13 & 14 is designed to operate from a d.c. supply voltage of up to 35V.

#### Hazardous Area Terminals 1 to 6 (forming part of the same intrinsically safe circuit)

$$\begin{array}{ll} U_o = 6.6V & C_i = 0 \\ I_o = 76mA & L_i = 0 \\ P_o = 0.13W & \end{array}$$

#### Hazardous Area Terminals 3 w.r.t. 1 (WITHOUT the Cold Junction Compensation (CJC) plug fitted)

$$\begin{array}{ll} U_o = 1.1V & C_i = 0 \\ I_o = 7mA & L_i = 0 \\ P_o = 2mW & \end{array}$$

#### Hazardous Area Terminals 3, 2 & 1 (with or without CJC plug fitted)

$$\begin{array}{ll} U_o = 6.6V & C_i = 0 \\ I_o = 10mA & L_i = 0 \\ P_o = 17mW & \end{array}$$



Programming / Configuration Port (Jack Socket)

$$\begin{aligned}
 U_o &= 8V & U_i &= 9.1V \\
 I_o &= 14.6mA \\
 P_o &= 26mW \\
 C_i &= 0 \\
 L_i &= 0
 \end{aligned}$$

The capacitance and either the inductance or the inductance to resistance ratio (L/R) of the hazardous area load connected to hazardous area terminals 1 to 6 and the programming / configuration port must not exceed the following values:

GROUP	CAPACITANCE ( $\mu$ F)	INDUCTANCE (mH)	OR	L/R RATIO ( $\mu$ H/ohm)
Hazardous Area Terminals 1 to 6				
IIC	22	6.42		288
IIB**	500	25.6		1,057
IIA	1,000	53.0		2,228
I	1,000	77.2		3,402
Programming / Configuration Port (Jack Socket)				
IIC	0.367	153		349
IIB**	2.15	591		1,355
IIA	8.8	1,000		1,453
I	12.32	1,000		1,453

\*\* Group IIB parameters also applicable for associated apparatus [Ex ia Da] IIIC

Notes:

- The above load parameters apply when one of the two conditions below is given:
  - the total  $L_i$  of the external circuit (excluding the cable) is  $< 1\%$  of the  $L_o$  value or
  - the total  $C_i$  of the external circuit (excluding the cable) is  $< 1\%$  of the  $C_o$  value.
- The above parameters are reduced to 50% when both of the two conditions below are given:
  - the total  $L_i$  of the external circuit (excluding the cable) is  $\geq 1\%$  of the  $L_o$  value and
  - the total  $C_i$  of the external circuit (excluding the cable) is  $\geq 1\%$  of the  $C_o$  value.

The reduced capacitance of the external circuit (including cable) shall not be greater than  $1\mu$ F for Groups IIB, IIA & I and 600nF for Group IIC.

**16 Report Number**

GB/BAS/ExTR16.0237/00

**17 Specific Conditions of Use**

None

**18 Essential Health and Safety Requirements**

In addition to the Essential Health and Safety Requirements (EHSRs) covered by the standards listed at item 9, the following are considered relevant to this product, and conformity is demonstrated in the report:

Clause	Subject	Compliance
1.2.7	Protection against other hazards (LVD type requirements, etc.)	Manufacturer responsibility
1.2.8	Overloading of equipment (protection relays, etc.)	User/Installer responsibility
1.4.1	External effects	User/Installer responsibility

Clause	Subject	Compliance
1.4.2	Aggressive substances, etc.	User/Installer responsibility

**19 Drawings and Documents**

New drawings submitted for this issue of certificate:

Number	Sheet	Issue	Date	Description
CI4573-5	1 of 1	2	7.16	MTL4573 Certification Label Details – Baseefa – Ex i

The above drawing is associated and held with IECEx BAS 14.0081 Iss. 2

Current drawings which remain unaffected by this issue:

Number	Sheet	Issue	Date	Description
CI4500-100	1 of 1	2	1.13	MTL 4500 Case
CI4573-1	1 of 1	2	10.14	Circuit Diagram for MTL4573
CI4573-2	1 to 3	2	10.14	MTL4573 Parts List
CI4573-3	1 of 1	2	10.14	MTL4573 Track Layout
CI4573-4	1 & 2	2	10.14	MTL4573 Component Layout
CI4573-6	1 of 1	1	10.13	PCB Detail for TPL301

The above drawings are associated and held with IECEx Certificate No. IECEx BAS 14.0081

**20 Certificate History**

Certificate No.	Date	Comments
Baseefa14ATEX0157	2 July 2014	The release of the prime certificate. The associated test and assessment against the requirements of EN 60079-0: 2012 and EN 60079-11: 2012 is documented in Certification Test Report No. GB/BAS/ExTR14.0163/00.
Baseefa14ATEX0157/1	13 November 2014	To permit minor circuit and PCB changes not affecting the original assessment.  The associated assessment is documented in Certification Report No. GB/BAS/ExTR14.0323/00.
Baseefa14ATEX0157 Issue 2	26 September 2016	This issue of the certificate incorporates previously issued primary & supplementary certificates into one certificate and confirms the current designs meet the requirements of EN 60079-0: 2012 + A11: 2013 & EN 60079-11: 2012.  The certificate also permits the manufacturer's name to be changed on page 1 of the certificate and on the equipment marking.  The associated assessment is documented in Certification Report No. GB/BAS/ExTR16.0237/00.

For drawings applicable to each issue, see original of that issue.